



**Termoplam Ltd.
Testing laboratory**

**Page number: 1
Number of pages: 12**

Republic of Bulgaria, Sofia,
<http://www.termoplam.eu>, e-mail: termoplam2011@abv.bg, GSM 0885 449 216

Test Report

**№ 238
10.08.2022**

I. NAME AND SIGNATURE OF THE TESTED SAMPLE:

Production series (range)-ECONOMIC S: "ECONOMIC S 26", "ECONOMIC S 33", "ECONOMIC S 40", "ECONOMIC S 55 and ECONOMIC S 65" ;

II. NAME AND DESCRIPTION OF THE TESTED SAMPLE(S):

Series of wood heating boilers (range) "ECONOMIC S": with a rated thermal output of 26 kW to 65 kW, one unit per test.

III. LEGAL DOCUMENT: EN 303-5:2021, EN 304:2017, EN 45001 and EN ISO/IEC 17025:2018.



Picture of the sample

IV. QUANTITY OF THE TESTED SAMPLES: The samples from the product range ECONOMIC S. One boiler for each sample of the product range.

V. MANUFACTURER: ABC PROIZVOD d.o.o; Miloša Obrenovića 2; 31000 Užice, Serbia.

VI TEST APPLICANT: ABC PROIZVOD d.o.o; Miloša Obrenovića 2; 31000 Užice, Serbia.


VII. PURPOSE AND OBJECT OF THE TEST:

Heating boiler thermal test for defining of:

- 7.1. Nominal heat output;
- 7.2. Test for determining heating boiler efficiency.
- 7.3. Determining emissions from the heating boiler.
- 7.4. Pressure test of the boiler plumbing parts.
- 7.5. Calculation of the seasonal space heating emissions.
- 7.6. Calculation of the seasonal space heating energy efficiency.
- 7.7. Calculation of the energy efficiency index (EEI).

VIII. TECHNICAL FEATURES

economic s



TECHNICAL DETAILS	TYPE OF BOILER							
	ABC26	ABC33	ABC40	ABC55	ABC63	ABC75	ABC100	ABC130
Power (kw)	26	33	40	55	65	75	100	130
Amount of water (l)	59	68	84	93	108	120	145	188
Mass (kg)	241	254	305	325	359	414	489	550
a (mm)	595	595	605	505	690	710	745	800
b (mm)	R5/4	R5/4	R5/4	R5/4	R6/4	R6/4	R2	R2
c (mm)	ø160	ø160	ø160	ø180	ø180	ø180	ø200	ø200
d1 (mm)	985	985	1110	1150	1220	1310	1455	1480
d2 (mm)	350	350	365	390	390	390	395	400
h1 (mm)	690	690	780	818	828	881	885	985
h2 (mm)	975	975	1055	1055	1095	1140	1140	1255
h1 (mm)	1060	1060	1190	1275	1280	1380	1525	1545
h2 (mm)	820	820	940	1005	1045	1110	1275	1290
Pressure (bar)	22	22	24	26	27	29	33	35

- 1. Top door
- 2. Lower door
- 3. Door for burner
- 4. Hole cover of the secondary draft
- 5. Connector for draft regulator R 3/4
- 6. Tube connector for return water
- 7. Tube connector for circulating water
- 7. Connector for heat exchanger
- 8. Chimney tube
- 9. Hole for cleaning and hole for gas burner
- 10. Hole for cleaning
- 11. Ash shaker
- 12. Valve regulating flue of gases
- 13. Hole for cleaning from top side
- 14. Ashtray's door
- 15. Ashtray
- 16. Connector for filling and emptying R 1/2

Scheme (drawing of the boiler)

8.1. Heat input Q_B - according to section 3.13 from EN 303-5:2021;

8.2. Thermal capacity P - according to section 3.6 from EN 303-5:2021;

8.3. Efficiency $\eta_k = P/Q_B$ - according to section 4.4.2 and 5.9.3 from EN 303-5:2021.

8.4. Boiler weight – without water/ volume of the water jacket:

8.4.1. ECONOMIC S 26 kW – 241 kg./ 59 l.;

8.4.2. ECONOMIC S 33 kW – 254 kg./ 68 l.;

8.4.3. ECONOMIC S 40 kW – 305 kg./ 84 l.;

8.4.4. ECONOMIC S 55 kW – 325 kg./ 93 l.;

8.4.5. ECONOMIC S 65 kW – 369 kg./ 108 l.;

IX. TEST CONDITIONS:

9.1. Executor: Termoplam Ltd. Sofia

9.2. Weather conditions: Ambient temperature t_L : 19/19°C ÷ 22/23°C (from 15°C to 30°C according to section 5.6.1 от EN 303-5:2021).

9.3. Starting Date: 05.08.2022 y. Date of completion: 10.08.2022 y.

9.4. Weight of the pilot fuel:

9.4.1. $B_n = 6,15 \div 15,25$ kg/h (wood at rated heating output for two semi periods of 2 hour with continuous combustion according according to 5.6.4.1 and 4.4.5 from EN 303-5:2021).

9.4.2. $B_{red} = 2,05 \div 4,62$ kg/h (wood at reduced heating output for two semi periods of 2 hour with continuous combustion according according to 5.6.4.1 and 4.4.5 from EN 303-5:2021).

9.5. Draft (low pressure in the flue pipe) $\leq 0,15 \div 0,28$ mbar (see section 4.4.4 from EN 303-5:2021).

9.6. Fuel type:

9.6.1. Wood with calorific value $H_u = 18320 \pm 60$ kJ/kg according to test report № 9298/30.05.2022 issued by the EUROTEST - Control SA (see section 5.3 and table 9 from EN 303-5:2021 and specified in the maintenance book).

9.7. Temperature of outgoing water 85,2/84,6°C ÷ 91.1/88,5°C (see section 5.7.2 from EN 303-5:2021).

9.8. Other conditions :

9.8.1. The test is made under the conditions quoted above and observing the following additional ones:

9.8.1.1. Complied with the safety measures according to EN 303-5:2021 and EN 304;

- 9.8.1.2. The tested samples meets the instruction for installation and operation according to EN 303-5:2021 and EN 304.
- 9.9. Used equipment - according to section 5.2 from EN 303-5:2021.
- 9.10. Recording devices:
- 9.10.1. Auxiliary devices: PC with software application package.

X. RESULTS FROM THE TEST:

10. Parametres.

- 10.1. Rated heating output of the boiler P_N according to section 3.7 from EN 303-5:2021.
- 10.2. Duration of the test rated heating output (two semi periods):
- 10.2.1. Wood duration of the test ≥ 2 h according to section 5.6.4.1 and 4.4.5 from EN 303-5:2021.
- 10.3. Maximum temperatures of the elements:
- 10.3.1 For heating boiler service:
- 10.3.1.1. Handle of the upper door $\leq 59,4/58,2$ °C – according to 4.3.7 from EN 303-5:2021;
- 10.3.1.2. Handle of the lower door $\leq 56,0/57,6$ °C – according to 4.3.7 from EN 303-5:2021.
- 10.4. Real values of the thickness measurement, etc. with additional certificates enclosed.
- 10.5. After the test of the plumbing parts at pressure $p_{outg}=2 \times PS=2 \times 3=6$ [bar] there are no leaks and visible deformations (elastic and plastic) in accordance with section 5.4.1 from EN 303-5:2021.
- 10.6. Temperature control and limiting divices according to section 4.3.9 from EN 303-5:2021:
The operating instructions state that a safety valve must be installed in the boiler.
In section 5, page 8 of the installation and operation instruction show and give detailed descriptions of connecting the boiler to open system type and to closed system type.
On page 8 picture 10 of the installation and operating instructions there is a description of how to connect a boiler to the open system using a safety valve. A connection diagram and the necessary elements are shown.
In page 8 picture 11 of the installation and operating instructions, a description is provided on how to connect the boiler to the closed system using a safety valve. The scheme shown is for connection to these elements.
- 10.7. For calculation of the values of Q_B , P and η_K are used formulas from items 5.9.1, item 5.9.2 and item 5.9.3.2 from EN 303-5:2021.
- * Values before the slash refer to the test at nominal power, and after it are for minimum power.

Table 1

Measurement	ECONOMIC S 26		ECONOMIC S 33		ECONOMIC S 40		ECONOMIC S 55		ECONOMIC S 65		Limit
	nom	min	nom	min	nom	min	nom	min	nom	min	
Regime	nom	min	nom	min	nom	min	nom	min	nom	min	-
t _A °C	195	184	214	189	218	197	229	209	236	215	
t _L °C	≤19	≤19	≤19	≤20	≤21	≤21	≤22	≤23	≤22	≤23	15÷30
t ₁ upper surface (average value)	≤50.0	≤49.3	≤55.5	≤52.1	≤57.1	≤52.4	≤61.7	≤57.6	≤63.7	≤57.8	≤60+t _L *= 83
t ₂ left wall (average value)	≤50.5	≤45.7	≤51.8	≤48.9	≤54.2	≤49.2	≤56.6	≤52.2	≤58.9	≤53.8	≤60+t _L *= 83
t ₃ right wall (average value)	≤51.6	≤47.2	≤52.3	≤51.0	≤52.6	≤51.2	≤58.9	≤51.9	≤60.3	≤54.4	≤60+t _L *= 83
t _{floor max}	≤36.5	≤35.1	≤38.9	≤38.6	≤39.9	≤38.7	≤41.5	≤41.6	≤42.2	≤41.0	≤ 80 *
t _{upper handle}	≤54.4	≤51.0	≤55.1	≤52.6	≤57.2	≤53.1	≤58.8	≤58.2	≤59.4	≤57.2	≤60+t _L *= 83
t _{lower handle}	≤53.1	≤51.1	≤53.7	≤52.7	≤54.4	≤52.0	≤55.7	≤53.8	≤56.0	≤57.6	≤60+t _L *= 83
P _{outg.} = 2xPS bar	6	6	6	6	6	6	6	6	6	6	= 6 bar
W ₁ m ³ /h	1105	360	1420	429	1750	580	2200	740	2450	760	-
t _v °C	85.2	84.6	86.5	85.5	86.5	85.7	91.1	89.1	90.1	88.5	-
t _R °C	65.0	64.2	66.5	65.5	66.8	66.0	69.5	68.0	67.2	66.4	70 ÷ 90
B _n kg/h	6.15	2.05	7.80	2.60	9.46	3.14	13.00	4.29	15.25	4.62	-
P kW	26.04	8.57	33.13	10.01	40.22	13.33	55.44	18.22	65.46	19.60	
Q _B kW	31.30	10.43	39.69	11.96	48.14	15.98	66.16	21.83	77.61	23.51	
η _k = P/Q _B [%]	83.19	82.16	83.47	83.69	83.55	83.41	83.79	83.46	84.34	83.37	class 4
CO mg/m ³ ** at 10% O ₂	501.4	478.2	516.3	509.9	537.5	533.3	574.5	554.8	640.7	578.2	≤700
CO ₂ % vol. part.	9.09	7.44	9.18	7.06	8.89	6.86	8.5	6.8	7.73	6.57	-
OGC mg/m ³ at 10% O ₂ ***	21.1	22.7	24.5	24.8	22.6	25.4	27.3	27.0	26.9	27.5	≤ 30
Dust mg/m ³ at 10% O ₂ ****	44.1	40.6	45.4	43.3	47.3	45.3	50.6	47.2	56.4	49.1	≤60
W % ****	≤30	≤30	≤30	≤30	≤30	≤30	≤30	≤30	≤30	≤30	-
O ₂ % vol. part.	11.6	13.3	11.5	13.7	11.8	13.9	12.2	14.0	13.0	14.2	10
NO _x mg/m ³ at 10% O ₂	162.4	147.0	167.2	156.8	174.1	164.0	186.1	170.6	189.1	177.8	
PN kW	26	-	33	-	40	-	55	-	60	-	-

* According to section 4.3.7 from EN 303-5:2021.

** Emission class 5 for the boiler using biogenic fuel with manual charging according to section 4.4.7 and table 7 from EN 303-5:2021.

*** Emission class 5 for the boiler using biogenic fuel with manual charging according to section 4.4.7 and table 7 from EN 303-5:2021.

**** Fuel – wood according to section 5.3, table 9 from EN 303-5:2021.

***** Emission class 5 for the boiler using biogenic fuel with manual charging according to section 4.4.7 and table 7 from EN 303-5:2021.

XI. Seasonal space heating emissions: acc. to table 8, Annex F from EN 303-5:2021, Annex II and Annex III of the REGULATION (EU) 2015/1189:

Table 2

Results	Model boiler					In accordance REGULATION (EU) 2015/1189. [mg/Nm ³]
	ECONOMIC S 26	ECONOMIC S 33	ECONOMIC S 40	ECONOMIC S 55	ECONOMIC S 65	
Dust [mg/Nm ³]	41.1	43.6	45.6	47.7	50.2	[PM] ¹ ≤ 60
CO [mg/Nm ³]	481.7	510.8	533.9	557.7	587.6	[CO] ² ≤ 700
OGC [mg/Nm ³]	22.5	24.7	24.9	27.0	27.4	[OGC] ³ ≤ 30
NO _x [mg/Nm ³]	149.3	158.4	165.5	172.9	179.5	[NO _x] ⁴ ≤ 200

Dust content of exhaust gases [PM] ¹ ≤ 60 mg/Nm³ for manual stoked boilers in accordance with point 1 (c), of Annex II of the REGULATION (EU) 2015/1189.

CO of exhaust gases [CO] ² ≤ 700 mg/Nm³ for manual stoked boilers in accordance with point 1 (e), of Annex II of the REGULATION (EU) 2015/1189.

OGC of exhaust gases [OGC] ³ ≤ 30 mg/Nm³ for manual stoked boilers in accordance with point 1 (d), of Annex II of the REGULATION (EU) 2015/1189.

NO_x of exhaust gases [NO_x] ⁴ ≤ 200 mg/Nm³ for biomass boilers in accordance with point 1 (f), of Annex II of the REGULATION (EU) 2015/1189.

XII. Seasonal space heating energy efficiency: acc. to Annex F from EN 303-5:2021, Annex II and Annex III of the REGULATION (EU) 2015/1189:

Table 3

Model boiler	Seasonal space heating energy efficiency η_s %	In accordance REGULATION (EU) 2015/1189 [η_s] [%]
ECONOMIC S 26	80.2	[η_s] ¹ ≥ 75
ECONOMIC S 33	80.5	[η_s] ² ≥ 77
ECONOMIC S 40	80.5	[η_s] ² ≥ 77
ECONOMIC S 55	80.8	[η_s] ² ≥ 77
ECONOMIC S 65	81.3	[η_s] ² ≥ 77

Where:

- η_s % - the seasonal space heating energy efficiency:

[η_s] ¹ ≥ 77 % for boilers with a rated heat output of more than 20 kW in accordance with point 1 (b), of Annex II of the REGULATION (EU) 2015/1189.

XII. Energy efficiency index (EEI): acc. to Annex F from EN 303-5:2021, Annex II and Annex VIII of the REGULATION (EU) 2015/1187:

Table 3

Model boiler	Energy efficiency index EEI	Energy efficiency class
ECONOMIC S 26	117	A+
ECONOMIC S 33	118	A+
ECONOMIC S 40	118	A+
ECONOMIC S 55	118	A+
ECONOMIC S 65	119	A+

The energy efficiency index is calculated according to:

- 12.1. The requirements and the formulas of ANNEX VIII of REGULATION (EU) 2015/1187;
- 12.2. The energy efficiency index is calculated on the database provided by manufacturer for boilers burning wood series (range) ECONOMIC S ;
- 12.3. The energy efficiency index is set for preferred fuel: wood according section 5.6.4.1 and section 5.3 from EN 303-5:2021.
- 12.4. Energy efficiency class is determined based on the energy efficiency index EEI according to Table 1 of ANNEX II of REGULATION (EU) 2015/1187.

XIII. ENCLOSURES:

- 13.1. Prints of the results from page 5.
- 13.2. Instruction for installation and operation - Yes.
- 13.3. Assembly drawing of the sample - 1.
- 13.4. Certificates (annexs A, B, C, D, and E): 5.



MANAGER:

(eng. Pl. Iliev)

NOTE:

The test results relate only to the tested samples.
Extracts from the test report can't be reproduced without written agreement of the testing laboratory.
This document is only informative.

Annex A

Declaration of conformity of steel sheet with a thickness of 5 mm

ISD DUNAFERR

CONFORMITY STATEMENT OF PRODUCER

ISO 9001

Page 1 (2)

				A07 Purch contract nr. ORDER FOR JANUARY 2013		Modification 0	
A01 Producer's Plant: ISD DUNAFERR ZRT, 2400 DUNAUVÁROS, VASMÚ TER 1-3		A02 Type of statement: 2.2-EN 10284-2004	B15 Validity: 2023.02.19	A10 Delivery date: 2013.02.19	A11 Date of issue: 2013.02.20	A08.1 Order No. Item: 0004209750-000002	A03 Statement No 0027171052/000005
		A06.1 Name of customer: Address of customer: Serbia,21000,NOVI SAD,21. TEMERINSKI PUT				A08.2 Contract No: 0004209750-000005	B02 Quality marking: P265GH Quality standards: DIN EN 10028-93 2 RESZ
A04 Metal stamp	A06.2 Place of destination: Luka Beograd, Serbia, 11000 BEOGRAD, Zorža Klemansija, 37		B01.1 Name of product: Hot rolled coil (Plain)				
		B05 Reference treatment of samples	B01.2 Dimension standard: EN 10051+A1				
		B01.3 Class: L					
		C05 Place of inspection: The testings were performed by the laboratory accredited by NAT under NAT-1-1037/2008 number.					
B03 Supplementary requirements		B04 Delivery terms of the product: Normalised					

IDENTIFICATION OF THE PRODUCT											
B07.1 Charge No.	C70 Steel prod. Procedure	C00 Sample No.	B07.2 Coil/Bundle No.	B08 Pieces (pc)	B12 Theoretical mass (t)	B13 Actual mass (t)	D52 Coiling temp.	B09 Width (mm)	B10 Thickness (mm)	B11 Length (mm)	B14 Total mass (t)
545568 545753	LD LD	90000314757 90000314758	671366000 671367000			22.230 22.780		1500±20	5		45.010
B06 Marking of the product: (Z04)											

Annex B
Certificate of the welding electrode



INSPECTION CERTIFICATE (3.1) - Chemical analysis
TEST REPORT (2.2) - Mechanical properties

Date: 2015-02-27

Certificate number: EC23783239 rev. 0

Our order: 028412
Our reference: Miroslav Abrsham
Customer number: HUE00047
Customer order date: 20150216

Your order: 03-2402-1
Your reference:
Your fax number:
Your e-mail:

Invoice address
ESAB KFT. (8703)
TERÉZ KRT. 55-57
BUDAPEST
HU-1062 HUNGARY
Hungary

Receiver of certificate

Delivery address
TEHNOALAT D.O.O
SLOBODE BB
SERBIA 34000
34000 KRAGUJEVAC
Serbia

DELIVERY Lot number: PV506024817B Quantity: 4 CT

PRODUCT

Brand: ESAB
Description: OK AristoRod 12.50 1.0mm 250kg
Item number: 1A50109320

CHEMICAL COMPOSITION

Actual results
acc to EN 10204 - 3.1

CLASSIFICATIONS

EN ISO 14341-A G 3Si1
EN ISO 14341-A G 38 3 C1 3Si1
EN ISO 14341-A G 42 4 M21 3Si1
SFA/AWS A5.18 ER70S-6
CAN/CSA-ISO 14341 B-G 49A 3 C G6
JIS Z 3312 YGW 12 (C1), (items
ending with H)

Wire/strip

Auxiliary:

C	0.07%
Si	0.89%
Mn	1.51%
P	0.012%
S	0.012%
Cr	0.07%
Ni	0.04%
Mo <	0.01%
Cu	0.06%
V <	0.01%
Al	0.001%
Ti+Zr	0.01%

MECHANICAL PROPERTIES

Typical data
acc to EN 10204 - 2.2

Standard: EN
Auxiliary: M21
Condition:

TENSILE

ReL	Rm	A4-A5
470 MPa	560 MPa	26 %

IMPACT

Temp	KV
-30 °C	70 J

COMMENTS

Product supplied under a QA Programme fulfilling the EN ISO 9001 standard.
This certificate is produced electronically and is valid without signature.
Please refer any queries to:

ESAB Kft, Terez krt. 55-57/C, H-1062, Budapest, +36 1 20 44 182

Annex C

Certificate of Quality requirements for fusion welding of metallic materials



ZERTIFIKAT

TUV SUD-W-1281.2021.001

Hersteller: **ABC PROIZVOD DOO UŽICE**
Miloša Obrenovića 2
RS – 31000 Užice

Fertigungsstätte(n): **Miloša Obrenovića 2**
RS – 31000 Užice

Der oben genannte Hersteller erfüllt die

**umfassenden Qualitätsanforderungen für das
Schmelzschiessen von metallischen Werkstoffen**

nach

EN ISO 3834-2

Auftragsnummer: 3425689

gültig bis: April 2024

München, 27. April 2021

Zertifizierungsstelle
Werkstoff- und Schweißtechnik


Klaus Schlotterer



EQ3106888 TÜV SÜD Industrie Service GmbH, Westendstraße 199, 80 666 München, Deutschland

ZERTIFIKAT ◆ CERTIFICATE ◆ ЗЕРТИФІКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Annex D
Certificate of Environmental management system



Certificate

No
19024

declaring that enterprise



Milosa Obrenovica 2, Uzica, Republic of Serbia

has established ENVIRONMENTAL MANAGEMENT SYSTEM
in accordance with the requirements of the standard:
SRPS ISO 14001:2015

which is identical with:
ISO 14001:2015

The scope of certification:

Factory for heating boilers, thermo technical equipment
and machine metal treatment.

Valid until:
21-Aug-2022

Place and date of issue:
Nis, 22-Aug-2019 v1.0 e



General manager:

Vladimir Yukašinović, M.Sc.EE.

Annex E
 Technical data sheet for the seal



Description

Bioglass packing is a gasket made by braiding Texpack® E-type glass fibres of 9 microns. It has a blanket core made of ceramic-free ecological fibre. The combination of the technical characteristics of the glass fibres (for the external sleeve, high mechanical and heat resistance), the softness and the flexibility make this type of gasket particularly suitable where high temperature seals are required.

Applications

Kilns and furnaces for ceramics and bricks, industrial furnaces, boilers, insulation of piping and wiring, aluminium and steel industry, other types of seals.

Characteristics of Bioglass	
Outer sleeve	glass yarn textured type E 9 µ tightly woven braid
Core	blanket of ecological material

Chemical analysis of the glass yarn		
Aluminium silicate	Al ₂ O ₃	1 - 4 %
Silica oxide	SiO ₂	62 - 67 %
Calcium oxide+ Magnesium oxide	CaO+MgO	9 - 12 %
Boron oxide	B ₂ O ₃	3 - 6 %
Alkali content	Na ₂ O+K ₂ O	15 - 17 %
Iron oxide	Fe ₂ O ₃	0 - 1 %
Phosphorus pentoxide	P ₂ O ₅	0 - 1 %

TECHNICAL DATA SHEET

Rev. 03 - 30/09/2015

7225 C
Bioglass

Characteristics	
Colours	light green
Chemical stability	excellent chemical stability resisting attack from most corrosive agents. Exceptions are fluorides, phosphoric acids and concentrated alkalis.
Melting point	1260°C
Long term operating temperature:	
- reinforced with steel wire	1050°C
- reinforced with glass threads	650°C
Loss on ignition at high temperature	<20%

Standard sizes	
diameter mm	rolls m
8	100
10	100
12	50
15	50
16	50
18	50
20	50
22	50
25	50
30	25
35	25
40	25
50	25

SQUARE AND RECTANGULAR SECTIONS ARE AVAILABLE ON REQUEST